

Retrievable Lagoon Aeration System Recommended Upgrade Options

The following optional equipment and features can be added to your equipment. Please indicate the items you would like to add, and AerResearch will recommend specifications which will require that they be included in your bid price.

1. Adjustable aerators, or
2. Suspended aerators, or
3. Floor-mounted aerators.
4. Levelable adjustable aerators.
5. Stainless steel cables instead of polypropylene ropes.
6. Unions on feedlines so that aerators can be removed and replaced.
7. Valves on feedlines so that air flow can be stopped when aerators are removed.
8. Deluxe float assemblies with stainless steel spring-loaded connectors and polyurethane fill.
9. EPDM vacuum hose instead of polyethylene pipe.
10. PVC instead of polyethylene laterals.
11. Suspended instead of floating laterals, or
12. Suspended instead of floor-mounted laterals.
13. Rigid instead of flexible feedlines.
14. Threaded instead of welded connections.
15. Fiberglass-reinforced polyurethane instead of PVC fittings.
16. Add ___ more weights to each flexible feedline.
17. Increase thickness of polyethylene pipe from DR-___ to DR-___.
18. Increase thickness of PVC pipe from Sch. ___ to Sch. ___.
19. Reusable worm-gear membrane clamps instead of crimp clamps.
20. Extra ___ day(s) of field service.
21. Extra ___ trips for field service.

